

# Hite associates

ARCHITECTURE / PLANNING / TECHNOLOGY

## ADDENDUM NO. 2

September 23, 2024

Project:       **East Carteret High School Art & Foods Lab**  
                  **Carteret County Schools**

**TO:   ALL BIDDERS**

*The following items clarify, add to, delete from, and / or otherwise change and supersede information previously issued to you in the bidding documents for the referenced project. Please read them carefully and adjust your bid accordingly.*

*Please note that addendums, and all revised documents are available via Hite Associates website [www.hiteassoc.com](http://www.hiteassoc.com) under the "Contractor Resources" link.*

## ADDENDUM NO. 2

1. Area vendor for NOTIFIER fire alarm is SCI of Greenville, NC.
2. Cord reels in the FOODS LAB are by the Electrical Subcontractor, per the schedule on Sheet A-710. Exhaust Hood and Fire Suppression system are by Mechanical Subcontractor, also this schedule.
3. Electrical subcontractor is responsible for data boxes and raceways to above acoustical lay in ceilings. Owner will provide data cabling and faceplates.
4. Existing Kiln is 240V – 1PH, 2P – 50A breaker is correct. No third conductor indicated on the home run feeder – should read "AR-1,3".
5. Sheet M711: Revised Make-Up Air Unit location and ductwork routing to Foods Lab Hood.
6. Sheet M712: Revised gas pipe routing to Make-Up Air Unit.

END OF ADDENDUM NO. 1



---

James G. Hite, AIA, Project Architect  
Hite Associates, PC

BIDDERS PLEASE NOTE THAT REFERENCED REVISED DOCUMENTS AND DRAWING REVISIONS ARE MARKED AS SUCH ON THE REVISION BLOCK ON THE PLANS AND ARE TO BE ACCESSED ON THE HITE ASSOCIATES WEBSITE.

ATTACHMENTS:

M-711, M-712

Revised / Added Documents:

SPEC SECTION 09510 Acoustical Ceiling Systems

SPEC SECTION 01056 Allowance

A-701	M-713
A-702	M-714
A-703	M-715
A-709	M-716
A-710	M-717
M-701	M-718
M-702 (OMITTED)	E-002
M-711	E-701
M-712	E-711

cc: All Bidders / Richard Paylor / Kenny Pedersen / Tom Owens

dist.: JGH / RBE / WP / File: Bids & Addenda