



514 Market Street, Wilmington, NC 28401
phone 910.762.2621
www.bmharch.com

May 7, 2025

ADDENDUM #2

Coastal Carolina Community College
Pedestrian Walkway Roof Replacement
Jacksonville, North Carolina

This addendum forms a part of the contract documents and modifies the original drawings and project manual dated March 26, 2025. The enclosed additions, deletions, corrections, and changes shall be as binding as if incorporated in the original documents. All General Conditions, Special Conditions, etc. as originally specified shall apply to these items. Acknowledgment of receipt of this addendum will be required as part of the contract agreement.

Item 1 **The bid date, time, and place remain the same:** The bid will be held on Thursday, May 15, 2025, at 2:00 pm in the Conference Room of the Institutional Support Services Building at Coastal Carolina Community College, 444 Western Boulevard, Jacksonville, North Carolina 28546.

Item 2 **Contract Documents - Clarification:** In areas where the new roof abuts existing walls with ACM metal panels, the construction documents' intent is for the lower ACM panels to be removed and replaced with smaller ACM panels. After the roof level has been raised, lower ACM panel replacement is required to construct the wall flashing details as delineated in the documents.

Bowman Murray Hemingway Architects, PC

A handwritten signature in black ink, appearing to read 'John Murray', written over a horizontal line.

John Murray, AIA