



514 Market Street, Wilmington, NC 28401
phone 910.762.2621
www.bmharch.com

May 29, 2025

ADDENDUM #4

Coastal Carolina Community College
Institutional Support Services Building Generator Replacement
SCO # 24-28038-01A
Jacksonville, North Carolina

This addendum forms a part of the contract documents and modifies the original drawings and project manual dated April 16, 2025. The enclosed additions, deletions, corrections, and changes shall be as binding as if incorporated in the original documents. All General Conditions, Special Conditions, etc., as originally specified, shall apply to these items. Acknowledgment of receipt of this addendum will be required as part of the contract agreement.

Item 1 **The bid date, time, and place remain the same:** The bid will be held on Thursday, June 5, 2025, at 2:00 pm in the Conference Room of the Institutional Support Services Building at Coastal Carolina Community College, 444 Western Boulevard, Jacksonville, North Carolina 28546.

Item 2 **Drawings:** Drawings Sheet E0.4, E2 – New Work Power Riser Diagram. Automatic Transfer switch enclosure to be NEMA-3R in lieu of NEMA-4 stated.

Bowman Murray Hemingway Architects, PC

A handwritten signature in black ink, appearing to read 'John Murray'.

John Murray, AIA